

Microgrid Distributed Generation and Storage

Final Report by: Dan Craig
 Jesus De La Cruz
 Jacob Dolan

Faculty Advisor - Dr. Herb Hess

Graduate Advisor - Jordan Scott

Fall 2016 - Spring 2017

Table of Contents

| | |
|---|-----------|
| Table of Contents | 1 |
| Executive Summary | 2 |
| Background | 2 |
| Problem Definition | 3 |
| Project Goals: | 3 |
| Project Deliverables: | 3 |
| Project Plan | 3 |
| Roles and Responsibilities: | 3 |
| Project Timeline: | 4 |
| Analysis of Renewable Energy Resources: | 5 |
| Improving Assets: Hospital Generator Fuel Conversion | 6 |
| Solar Panels | 7 |
| New Energy Storage | 8 |
| Grid Synchronization: | 10 |
| Results | 12 |
| Future Work | 13 |
| References | 14 |
| Appendices | 16 |

Executive Summary

Smart Spokane is working with Avista to empower the anticipated Spokane smart grid by laying the groundwork for solar roofs, battery installations, and generator fuel conversions. This smart grid will increase the control and reliability of the Spokane grid which was found lacking after the 2015 windstorm. The smart grid will enable downtown Spokane to isolate itself from any power surges and blackouts that affect the area outside of the microgrid.

Smart Spokane has planned for the 2 hydroelectric dams, 17,000 solar panels divided among 38 locations, 18 converter hospital generators, in conjunction with 29 battery installations will provide 9 critical services standard operating power during grid isolation.

The smart grid will increase reliability of the Spokane grid by protecting it from blackouts and surges that affect the rest of the system. During daily use, the increase in generation should help to lower energy costs after the new assets have been fully paid for.

Background

On November 17, 2015, a strong windstorm hit the Spokane area. The strong winds severed the power transmission lines from the Columbia River generating stations. This event led to a large scale power outage for the area. Avista Utilities crews fully restored power service after four long weeks.

This event revealed a need for a more reliable system. Meanwhile in other parts of the country a new system was being developed, the microgrid. The microgrid is a subsection of the larger power grid that can isolate itself from the larger whole in case of emergency and supply power to its loads.

Avista Utilities is working with federal programs such as Smart Cities to develop a smart grid for downtown Spokane. As a part of the smart grid package, a microgrid will be developed for the downtown area. These developments will improve the reliability of the power service and therefore raising the level of service quality, while also decrease cost of damages caused by blackouts.

Problem Definition

Project Goals:

Due to the lack of a backup system that could sustain critical loads in downtown Spokane, a micro-grid system has being proposed. The micro-grid design consists of four main power supplies; solar panels, battery banks, diesel/natural gas generators, and two hydropower plants. Along with this is a synchronization system, detailed budget, and a PowerWorld simulation.

Project Deliverables:

- PowerWorld simulation of the microgrid
- Photovoltaic (PV) locations and power output available
- Battery location(s) and detailed specs
- Gridtie inverters specs, brand, and type for PV and battery banks
- Options for converting hospital generators to natural gas
- Specs of the chosen synchronizer to parallel hospital generators with the grid
- Detailed cost estimation for design installation

Project Plan

Roles and Responsibilities:

Jesus De La Cruz:

Team Leader - represent the team in client / public meetings

Treasurer - manage the budget, keep track of all receipts, and seek alternative purchases

Dan Craig:

Primary Client Contact - correspond and update the client

Meeting Organizer - schedules meetings and reserves the meeting room

Jacob Dolan:

Editor - review documentation and advise changes

Secondary Client Contact - primary client contact backup

Driver - licenced University of Idaho driver for team field trips

Rotating Roles:

Master of Ceremonies - create the meeting agenda, distribute it, and lead the meetings

Secretary - record the meeting minutes and distribute it

Project Timeline:

Table 1: Project Timeline - 1st Semester

Smart Spokane Gantt Chart (1st Semester)





Table 2: Project Timeline - 2nd Semester

Smart Spokane Gantt Chart (2nd Semester)



Analysis of Renewable Energy Resources

A critical component of a functional microgrid is the distributed generation (DG). Downtown Spokane already has two hydroelectric dams to supply power. To supplement this current power supply the following renewable DGs were considered and a comparative matrix was built to represent the decision of main DG.

The criteria of the decision matrix was graded on a scale from 0-5 (5 high). The scores were averaged for each option and the highest score was chosen.

Solar Panels: Downtown Spokane contains plentiful roof space for solar panels and few towering buildings to cast shadows. This mature technology is already employed at the Avista solar farm.

Wind Turbines: Spokane is located in a valley which shelters it from the wind.

Wave Generators: This immature technology relies on the presence of waves to generate electricity. Spokane River does not generate enough waves and the Spokane City Council is adverse to additional hydroelectric generators.

Instream Generators: While the Spokane River which runs through downtown Spokane could be used for instream generators the Spokane City Council is adverse to additional hydroelectric generators because the river is a public domain and Instream generators would create an “eye sore” in what is historic downtown area.

Biomass: This would be a very reliable resource in the Spokane area. There is a local facility that could provide biomass for energy generation located near the airport.

Rain/Solar Generators: This generator is much like solar panels except for the added ability to generate energy from rainfall. This is a recent technology so market is immature. [4]

Table 3: Distributed Generation Decision Matrix

| Renewable Energy Comparative Matrix | | | | | | | | |
|-------------------------------------|----------|------|--------------|----------------------|-------------------|------------|-------------|-------------|
| Source of Energy | Location | Cost | Power Output | Environmental Impact | Client Preference | Complexity | Reliability | Total (0-5) |
| Solar Panel | 5 | 4 | 5 | 5 | 5 | 4 | 4 | 4.6 |
| Wind Turbine | 0 | 5 | 2 | 5 | 1 | 4 | 1 | 2.6 |
| Wave Generator | 1 | 1 | 1 | 5 | 2 | 1 | 1 | 1.7 |
| Instream Generator | 4 | 2 | 3 | 5 | 4 | 3 | 5 | 3.7 |
| Biomass | 5 | 1 | 1 | 3 | 3 | 3 | 5 | 3.0 |
| Rain/Solar Generator | 5 | 1 | 5 | 5 | 5 | 4 | 4 | 4.1 |

Improving Assets: Hospital Generator Fuel Conversion

There are currently 18 backup generators distributed in downtown Spokane among Sacred Heart, Deaconess, and Shriners Hospitals. Together all the generators can provide about 14.75 MW. This generation is significant and can be set in parallel to the microgrid to enhance power reliability. [8]

Currently, all the hospital backup generators are setup to feed only their respective facilities. There is no existing connection or method that can transfer the output to the local distribution system. See the Synchronization section for details of how power from these converted generators could be synchronized to the local grid.

The hospital generators are currently diesel-fueled. Because of environmental restrictions, the use of diesel generators is limited to short durations during emergencies. To increase the use of the generators, environmental standards require a change to a more eco-friendly fuel source such as natural gas. After the change, the generators will be recommissioned and approved for longer run times. It is anticipated that the conversion will allow the generators to offset the daily peak load and therefore reduce peak load rise of energy prices.

The University of Idaho Microgrid team has spoken with Avista representatives about a potential Avista Incentive Program for the hospitals to purchase and use generator conversion kits. The team has spoken with a Florida company, GFS Corp about their generator conversion kits. This company is experienced in converting commercial grade diesel generators to a hybrid of diesel and natural gas. Most of their projects provide the customer's old generators with a peak shaving capabilities. GFS Corp has the is able to perform this conversion for the hospital generators through distributors in Washington

According to a representative with the company, the conversion process will provide the following aspects to the newly converted engines:

- 1) Non-invasive retrofit. The existing engines will not need to be taken apart for any part of the conversion process. [5]
- 2) The engines will start up on diesel, then convert to a hybrid operation of diesel and natural gas. [5]
- 3) Maximum operation of 70% natural gas to 30% diesel. [5]
- 4) Conversion for one unit usually takes two days (one day to install and another day to re-commission). [5]
- 5) No power loss after the conversion process. [6]
- 6) Extends generator run time using pipelined natural gas [6]
- 7) Price quote for Caterpillar 3412 Engine located in Deaconess: ~ \$35,000 [5]

An estimated pricing table of the entire conversion is given in Appendix E. From the representative giving the price quote, the prices vary depending on KW rating and brand of the engine. Thus the pricing below is a rough estimate based off the quote for the engine given in the aspects list (Caterpillar 3412 750 kW) that is roughly \$35,000.

Solar Panels

Since the hydroelectric dams cannot supply enough power to the city, the generation will be supplemented with solar panels. This decision was influenced by the conversation with Randy, the Avista contact, who mentioned that the Spokane Event center had contacted Avista about installing solar panels.

The chosen solar panel is the Sunmodule Bisun SW 330 XL duo. A large percentage of Spokane roofs are horizontal and painted white, which are some of the ideal conditions for increasing the efficiency of the bifacial cells [11]. This solar panel will outshine the competitor brands during the sunny winter days where snow lies on the rooftops. While the snow cover on the front of the panels would block a single sided solar panel from operating, the dual-sided nature of the Bisun would gather more light on its opposing side from light reflection off the snow.




Figure 1: Sunmodule Bisun [12]

Using Google Earth, 38 locations were found for the Solar panels. These locations consist of the largest roofs in the same distribution zones the critical loads (Hospitals, jails, etc). Using the ruler tool of Google Earth and the dimensions of the solar panel, it is estimated that seventeen thousand solar panels can be placed in the first installation for a maximum power output of 5.6 MW.

Since the client did not provide an expected budget limit, the solar panels were divided into modules based on the distribution lines. It is expected that the client will implement one module at a time. [M1]

New Energy Storage

Energy storage is crucial for a microgrid since it eases the transition from the grid-connected mode to the grid-disconnected or “island” mode. This period allows the various customers time to shut down the processes and machines that would otherwise be damaged by the sudden drop or loss in power. The standard use of energy storage for this purpose is to charge the battery installations from the grid during normal operating conditions. Then the battery installations will be discharged later during an emergency. Depending on the energy storage, it could also store energy during low load to be later discharged during peak load.

The two options for MW energy storage were the standard Lithium-ion or Vanadium Flow batteries. The Vanadium Flow battery was chosen because it experiences no noticeable degradation of energy capacity from charge/discharge cycles. This trait allows for the secondary goal of peak load use for the batteries. Comparatively, the Lithium-ion is more energy dense but suffers from capacity degradation.

The team chose UniEnergy Technologies (UET), located in Mukilteo, WA, as the Vanadium Flow battery provider. This company has supplied Avista with the Vanadium Flow batteries in use at Schweitzer Engineering Laboratory in Pullman, WA. The battery system consists of 5 standard freight containers and can be easily relocated if needed because of the modular design. The batteries can also be double-stacked if needed.[16]

Specifications for UET Energy Storage System:

- * Weight: 375,000 Lbs
- * Space: 820 ft² (41'W X 20'L X 9.5'H)
- * 5 containers per battery module
- * 20 MW per acre, 40 MW per acre if double stacked
- * Roundtrip Efficiency: ~ 70%
- * Response Time: < 100 ms
- * Lifespan: 20 yrs
- * Unlimited Cycles
- * Today's cost for Implementation: ~ \$3.2 million

3 Operating Conditions:

- 1) $P_{peak1} := 600kW$
Discharge1 := 2-hr
Energy1 := $P_{peak1} \cdot \text{Discharge1} = 1.2\text{-MW}\cdot\text{hr}$
- 2) $P_{peak2} := 500kW$
Discharge2 := 4-hr
Energy2 := $P_{peak2} \cdot \text{Discharge2} = 2\text{-MW}\cdot\text{hr}$
- 3) $P_{peak3} := 275kW$
Discharge3 := 8-hr
Energy3 := $P_{peak3} \cdot \text{Discharge3} = 2.2\text{-MW}\cdot\text{hr}$



Figure 2: UET Battery Specifications [16]

System Power Cases:

The minimum number of UET batteries required was determined by analyzing the system power cases the seasonal balance of generation and the critical loads. The best-case and worst-case was developed. The worst-case scenario occurs during the summer when the air conditioning creates a high load draw while the river and hydroelectric generation is low. For this case, 29 battery sets are required to match the critical loads draw. The best-case scenario occurs during the spring during temperate climate and high river and hydroelectric generation. For this case, no batteries are needed since excess power would be generated.

The two cases give a range of the minimum batteries required to help the critical loads to run standard operation. Avista Utilities has the discretion to install as many or little batteries as they deem necessary. 29 battery modules will probably not be installed due to the heavy cost per installation.

The System Power Cases were based off of the data provided in Pavan Penkey's thesis, "Critical Load Serving Capability by Microgrid Operation". For the spring and summer scenarios, the peak daytime load for each critical load was taken to sum up the entire load draw for the seasons. Winter and fall seasons were analyzed but they fell in the middle of spring and summer in terms of amount of batteries needed for load matching. The information in the table below summarizes the findings and also aligns with the Powerworld model results in terms of MW provided by the batteries.


Table 4: Extreme point comparisons (best and worse case scenario) [8]

| SYSTEM POWER CASES | | | | |
|--|---------------------|--------------------|--------------------------|------------|
| | | | | |
| | LOADS | GENERATION | | |
| | Critical Loads (MW) | Photovoltaics (MW) | Hospital Generators (MW) | Hydro (MW) |
| Worst Case | 44.37 | 4.468 | 14.745 | 11 |
| Best Case | 39.4 | 3.839 | 14.745 | 23 |
| | | | | |
| | Worst Case | Best Case | | |
| Total Load (MW) | 44.37 | 39.4 | | |
| Total Generation (MW) | 30.213 | 41.584 | | |
| Load Profile Deficit (MW) | -14.157 | 2.184 | | |
| Batteries to Supply Load | 29 | 0 | | |
| * Batteries chosen are UET 500 kW for 4 Hours (2 MWhrs) | | | | |
| * Worst case is peak daytime load for highest load draw season and lowest generation season (Summer) | | | | |
| * Best case is peak daytime load for lowest load draw season and highest generation season (Spring) | | | | |

Grid Synchronization:

The micro-grid will be fed from the distributed generation system (DGS). The DGS needs to synchronize safely with the grid to distribute power without damaging any DGS components. The best option to achieve this is to use Gridtie Inverters for the photovoltaics (PV) and battery banks, and generator auto-synchronizers for the hospital generators.

Gridtie Inverter – This device is used to convert a DC supply to an AC supply with a matching frequency, voltage magnitude and phase of the local grid. The battery and PV gridtie inverters work the same way.



Figure

Figure 3: Gridtie Inverter Schematic

- a) The section boxed in blue on figure 1 shows how the PV is connected into the grid. When the PV supplies power, a boost converter amplifies the output of the PV using an algorithm of maximum power point tracking (MPPT). This allows the PV to operate at a point where it can supply the maximum power by adjusting its voltage and current to its best operating point. The output of the boost converter (V_{boost} , I_{boost}), is fed into a voltage source inverter, which transforms the DC supply into an AC supply. This output is then is fed into the grid. [1][2][9]
- b) The section boxed in green of figure 1 shows the gate controller of the IGBT. This controller handles the voltage source inverter (VSI) as well as the boost converter IGBT. The goal of this controller is to be able to take the measured grid values (frequency, voltage magnitude and phase) and generate a signal to control the gating of the VSI so that the AC output of the VSI matches the grids value. [1][2][9]

Generator Auto-Synchronizer – The diesel/natural gas generators will connect to the micro-grid using auto-synchronizers. This device will adjust the synchronous generator governors and exciters until it matches the frequency, voltage magnitude, and angle of the grid. At this point, the breakers that link the generators and micro-grid closes.




Figure 4: Generator Auto-synchronizer (GAS)

Figure 2 shows how a generator is synchronized into the system using a Generator Auto-Synchronizer (GAS). To start, the breaker that links the generator output and the micro-grid distribution line is open. Then the GAS reads through the connection leveled as “grid feedback.” Using this grid feedback values, the GAS starts adjusting the frequency by using the generator’s governor controls. This will set the generator output to have the same frequency as the grid. The GAS also adjusts the generator voltage amplitude output by controlling the generator exciter. [14][15]

The generators output reading is then fed back into the GAS to ensure close acceptance. The voltage output of the generators is adjusted to be slightly higher than of the micro-grid voltage so that the generators does not absorb any reactive power.

Finally when the micro-grid frequency and generator frequency are in phase or within the acceptance region, the breaker which links the generator output and the micro-grid distribution line closes and the synchronization process is complete.[14][15]

Results

Results

Table 5: Power and Price Results

| | Power | Price |
|-----------------------|-----------------------------|-----------------|
| Shriners hospital | 500kW | \$30,000.00 |
| Sacred Heart hospital | 10.36MW | \$400,000.00 |
| Deaconess hospital | 4.2MW | \$205,000.00 |
| Battery Banks | 29 MW (worse case scenario) | \$93,087,874.00 |
| Photovoltaic module 1 | 1.456MW | \$1,032,408.00 |
| Photovoltaic module 2 | 1.889MW | \$1,339,650.00 |
| Photovoltaic module 3 | 1.886MW | \$1,337,310.00 |
| Photovoltaic module 4 | 3.54kW | \$250,845.00 |

Future Work

This project has been divided into modules based on distribution lines. It is recommended that Avista confirms the boundaries of the modules. The Hospital module should be implemented first.

For future work more distributed generation sources could be considered. Solar roadways would be ideal for the large parking lots around the Veteran's Memorial Arena. Solar windows would be great for buildings with large glass walls. Solar tracking could be added to the current solar sites. New sources of biological based generation could be explored such as in the waste disposal plant.

The duration of any one or couple of these new works would be the same a senior design project. The cost of which would be about \$200 for program licenses and gas fuel.

References

- [1] Aurobinda Panda, M.K. Pathak, S.P. and Srivasta. 2012 “*Gridtie Inverter Control for Rooftop Photovoltaic,*” IEEE Power India Conference.
- [2] Amirnaser Yazdani and Reza Iravani. 2010. “*Voltage-Sourced converters in power systems.*” P160-240 grid imposed frequency VSC.
- [3] AP Systems. (n.d.). *YC500A Microinverter* [Brochure]. Author.
- [4] Choi, C. Q. (2016, April 06). Graphene Could Help Generate Power From Rain. Retrieved May 09, 2017, from <http://spectrum.ieee.org/energywise/green-tech/solar/graphene-could-help-generate-power-from-rain>
- [5] Dialogue with GFS Corp Representative: Diesel to Natural Conversion [Interview by D. Craig]. (n.d.).
- [6] GFS Corp. (n.d.). Natural Gas Conversions for High Horsepower Diesel Engines Offering Substantial Fuel Cost Savings and Cleaner Emissions. Retrieved February 09, 2017, from <http://www.gfs-corp.com>
- [7] Parker-Hannifin Corporation. (2014). *Power Conversion System for Energy Storage* [Brochure]
- [8] Penkey, P. K. (2016). *Critical Load Serving Capability by Microgrid Operation* (pp. 1-175, Rep.).
- [9] Sajib Chakraborty, Saila Ishrat Annie, and M.A. Razzak. 2014 “*Design of Single-Stage Buck and Boost Converters for Photovoltaic Inverter Application,*” IEEE Informatics, Electronics & Vision (ICIEV), 2014 international conference.
- [10] Schweitzer Engineering Laboratories. (2010-2017). *SEL-451-5 Protection, Automation, and Bay Control System* [Brochure]. Author.
- [11] Sunmodule Bisun Solar Panels. (n.d.). Retrieved May 09, 2017, from http://www.solarworld-usa.com/products-and-services/sunmodule-solar-panels#Sunmodule_Bisun
- [12] Sunmodule Bisun [Bisun-xl-duo-flat_front_back-web.png]. (n.d.). Retrieved January 1, 2017, from http://www.solarworld-usa.com/products-and-services/sunmodule-solar-panels#Sunmodule_Plus
- [13] *Sunmodule Bisun SW 330 XL DUO* [PDF]. (n.d.). SolarWorld.
- [14] Thompson, M. J. (2012). *Fundamentals and Advancements in Generator Synchronizing*

Systems (Rep. No. 9145). 65th Annual Conference for Protective Relay Engineers.

[15] Thompson, M. (2016). *Advancements in Synchronizing Systems for Microgrids and Grid Restoration* (Rep. No. 113974). 13th International Conference on Developments in Power System Protection.

[16] Uni.System. (n.d.). Retrieved October 10, 2016, from
<http://www.uetechologies.com/products/unisystem>

Referenced Client Supplied Material

[M1] *AVA_Microgrid_Area_Map* [Png]. (n.d.).

Appendices

APPENDIX A - SYNCHRONIZATION SYSTEM

Battery Gridtie Inverter [7]

| | |
|-------------------------------|--------|
| 890GTB-1800 | values |
| Input dc bus voltage (V) | 730 |
| Input dc bus voltage max (V) | 800 |
| Rater output up to 35°C (KVA) | 1800 |
| Rater output up to 50°C (KVA) | 1620 |
| Nominal output voltage (V) | 480 |
| Nominal output frequency (Hz) | 50/60 |
| Efficiency (%) | 98.7 |

Photovoltaic Gridtie Inverter [3]

| | |
|-------------------------------------|----------------|
| YC500A Microinverter | values |
| MPPT voltage range (V) | 22-45 |
| Max input current (A) | 12 |
| Rated output power (W) | 500 |
| Max output current (A) | 2.08 |
| Nominal output voltage (V) | 240 |
| Nominal output frequency/range (Hz) | 60 / 59.3-60.5 |
| Peak efficiency (%) | 95.5 |
| Nominal MPP tracking efficiency (%) | 99.5 |




Generator Autosynchronizer [10]

| | |
|---|--|
| SEL-451-5 Autosynchronizer | values |
| Sensing: Generator and bus PT ratio Generator nominal voltage (V) Bus nominal voltage (V) | 1:10,000 turns 20-200 secondary 20-200 secondary |
| Initiate Autosync: Upper and lower frequency limit range (Hz) Upper and lower voltage limit range (per unit) | 45-65 0.8-1.2 pu |
| Close Acceptance: Slip Frequency range (Hz) Rate of change of the frequency range (Hz/s) Parallel close/operator permissive window (deg) Dead bus voltage (per unit) Breaker close time (cycles) | 0.025-0.5 0.01-1 3-80 0.01-0.5 1-30 |
| Control: Frequency and voltage correction pulse (s) Frequency and voltage pulse width (s/Hz) | 1-30 0.01-100 |

APPENDIX B - COST ESTIMATION

| Implementation Expenses | | |
|-------------------------|---|------------------------|
| #UNITS | ITEMS | ACTUAL |
| 1 | solar Panel unit (500W) | \$234.00 |
| 4412 | solar Panel module 1 | \$1,032,408.00 |
| 5725 | solar Panel module 2 | \$1,339,650.00 |
| 5715 | solar Panel module 3 | \$1,337,310.00 |
| 1072 | solar Panel conv&theater | \$250,848.00 |
| 1 | grid-tie Inverter (solar) unit | \$280.00 |
| 16924 | grid-tie Inverter (solar) total | \$4,738,720.00 |
| 2 | Module 1&2 Transformer | \$20,000.00 |
| | total solar system | \$8,718,936.00 |
| 1 | Battery bank (unit) | \$3,200,000.00 |
| 14 | Battery bank location 1 | \$44,800,000.00 |
| 15 | Battery bank location 2 | \$48,000,000.00 |
| 1 | grid-tie Inverter (Battery) unit | \$1,469.00 |
| 6 | grid-tie Inverter (Battery) total | \$8,814.00 |
| 1 | Battery step-up transformer unit | \$9,302.00 |
| 30 | Battery step-up transformer total | \$279,060.00 |
| | total battery system | \$93,087,874.00 |
| 1 | Cummins (1250kW) Diesel to Natural gas Conv. kit (unit) | \$45,000.00 |
| 1 | Cummins (250kW) Diesel to Natural gas Conv. kit (unit) | \$25,000.00 |
| 1 | Silver eagle (200kW) Diesel to Natural gas Conv. kit (unit) | \$25,000.00 |
| 1 | Onan (500kW) Diesel to Nutural gas Conv. kit (unit) | \$30,000.00 |
| 1 | Detroit (750kW) Diesel to Nutural gas Conv. kit (unit) | \$35,000.00 |

| #UNITS | ITEMS | ACTUAL |
|--------|---|-------------------------|
| 1 | Diesel to Nutural gas Conv. kit Shrines | \$30,000.00 |
| 12 | Diesel to Nutural gas Conv. kit Sacred Heart | \$435,000.00 |
| 1 | Autosynchronizer unit | \$4,500.00 |
| 4 | Autosynchronizer total | \$18,000.00 |
| 1 | Autosynchronizer CD | \$2,500.00 |
| 1 | Autosynchronizer grid feedback VT unit | \$254.14 |
| 1 | Autosynchronizer grid feedback CT unit | \$343.59 |
| 4 | Autosynchronizer grid feedback VT total | 1016.56 |
| 4 | Autosynchronizer grid feedback CT total | 1374.36 |
| 1 | Autosynchronizer Gen. feedback VT unit | \$254.14 |
| 19 | Autosynchronizer Gen. feedback VT toal | \$4,828.66 |
| | total generator system | \$697,719.58 |
| | Total Expenses | \$102,504,529.58 |



APPENDIX C - SOLAR PANELS DATASHEET [13]

Sunmodule[®] Bisun SW 330 XL DUO



PERFORMANCE UNDER OPTIMIZED CONDITIONS

| Energy boost | | 6 % | 10 % | 20 % | 25 % |
|-----------------------------|--------------|---------|---------|---------|---------|
| Maximum power | P_{max} | 348 Wp | 361 Wp | 391 Wp | 406 Wp |
| Open circuit voltage | V_{oc} | 46.9 V | 46.9 V | 46.9 V | 46.9 V |
| Maximum power point voltage | V_{mp} | 38.0 V | 34.7 V | 38.0 V | 34.7 V |
| Short circuit current | I_{sc} | 10.08 A | 10.46 A | 11.41 A | 11.89 A |
| Maximum power point current | I_{mp} | 9.21 A | 9.56 A | 10.43 A | 10.86 A |
| Module efficiency | η_{mod} | 17.46 % | 18.08 % | 19.60 % | 20.36 % |

PERFORMANCE UNDER STANDARD TEST CONDITIONS (STC)*

| | | |
|-----------------------------|--------------|---------|
| Maximum power | P_{max} | 330 Wp |
| Open circuit voltage | V_{oc} | 46.9 V |
| Maximum power point voltage | V_{mp} | 38.0 V |
| Short circuit current | I_{sc} | 9.51 A |
| Maximum power point current | I_{mp} | 8.69 A |
| Module efficiency | η_{mod} | 16.54 % |

Measuring tolerance (P_{max}) traceable to TUV Rheinland: $\pm 2\%$
(TUV Power controlled)

*STC: 1000 W/m², 25 °C, AM 1.5

PERFORMANCE AT 800 W/m², NOCT, AM 1.5

| | | |
|-----------------------------|--------------|---------|
| Maximum power | P_{max} | 246 Wp |
| Open circuit voltage | V_{oc} | 42.9 V |
| Maximum power point voltage | V_{mp} | 34.7 V |
| Short circuit current | I_{sc} | 7.68 A |
| Maximum power point current | I_{mp} | 7.02 A |
| Module efficiency | η_{mod} | 12.34 % |

Minor reduction in efficiency under partial load conditions at 25 °C: at 200 W/m², 95 % ($\pm 1\%$) of the STC efficiency (1000 W/m²) is achieved.

COMPONENT MATERIALS

| | |
|-------------------------|---|
| Cells per module | 72 |
| Cell type | bifacial duo |
| Cell dimensions | 6.17 x 6.17 in (156.75 x 156.75 mm) |
| Front | Tempered safety glass (EN 12150) |
| Back | transparent backsheet |
| Frame | clear anodized aluminum |
| J-Box | IP65 |
| Connector | PV wire per UL4703 with UTX/H4 connectors |
| Module fire performance | (UL1703) Type 1 |

DIMENSIONS / WEIGHT

| | |
|--------|--------------------|
| Length | 78.46 in (1993 mm) |
| Width | 39.4 in (1001 mm) |
| Height | 1.3 in (33 mm) |
| Weight | 47.6 lbs (21.6 kg) |

THERMAL CHARACTERISTICS

| | |
|--------------|---------------|
| NOCT | 46 °C |
| TK I_{sc} | 0.042 % / °C |
| TK V_{oc} | -0.304 % / °C |
| TK P_{max} | +0.43 % / °C |



PARAMETERS FOR OPTIMAL SYSTEM INTEGRATION

| | |
|------------------------------|--|
| Power sorting | ± 0 Wp / ± 5 Wp |
| Maximum system voltage NEC | 1000 V or 1500 V - Specify when ordering |
| Maximum system voltage SC II | 1000 V |
| Maximum reverse current | 25 A |
| Load / dynamic load | 50 / ± 50 psf (2.4 / ± 2.4 kN/m ²) |
| Number of bypass diodes | 3 |
| Operating range | +40 to +85 °C |

INSTALLATION PARAMETERS FOR MAXIMUM YIELD

For maximum system yield and optimum performance ratio we recommend the following installation guidelines:


- Highly reflective background surface like white concrete, bright roof covering membrane, trapezoidal roof or limestone ground
- Maximize module distance to ground
- Mounting system with low shading of backside
- Sufficient distance between rows to avoid shading
- Prefer landscape mounting



All units provided are imperial. SI units provided in parentheses.
SolarWorld AG reserves the right to make specification changes without notice.
This data sheet complies with the requirements of EN 50380.

SW-01-7127US 160906

APPENDIX D- POWERWORLD MODEL[8]



APPENDIX E - DIESEL TO NATURAL GAS GENERATOR CONVERSION KIT PRICES [5]

| Deaconess | | | |
|----------------|-------------------------------|------|-------------------------------|
| Manufacturer | Model/Serial # | KW | Price Estimate for Conversion |
| Silver Eagle | Volvo Penta TD 121 GG | 200 | \$25,000 |
| Caterpillar | 1000SC2/CAT00C32AJAZ00218 | 1000 | \$40,000 |
| Caterpillar | 1000SC2/CAT00C32ESAZ00269 | 1000 | \$40,000 |
| Caterpillar | 3412 / 00000V9EP00895 | 750 | \$35,000 |
| Caterpillar | 3412 / 00000V9EP00896 | 750 | \$35,000 |
| Onan | Cummins KTTA19G2 / 37130849 | 500 | \$30,000 |
| | | | \$205,000 |
| Sacred Heart | | | |
| Manufacturer | Model/Serial # | KW | Price Estimate for Conversion |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Cummins | Possibly DF4961842/G010265453 | 1250 | \$45,000 |
| Detroit Diesel | Possibly DF4961842/G010265453 | 750 | \$35,000 |
| Cummins | Possibly DF4961842/G010265453 | 260 | \$25,000 |
| Caterpillar | Possibly DF4961842/G010265453 | 35 | Not Economical |
| Caterpillar | Possibly DF4961842/G010265453 | 250 | 25,000 |
| | | | \$400,000 |
| Shriners | | | |
| Manufacturer | Model/Serial # | KW | Price Estimate for Conversion |
| Caterpillar | 3412/81Z09461 | 500 | \$30,000 |
| | | | \$30,000 |
| | | | |
| | | | \$635,000 |